

Attestation of Conformity

No.: M08 08P10021 0033



Holder of Certificate: KLAS Isıtma Soğutma Klima San. ve Tic. Ltd.Şti.
Simge Caddesi No: 19
Yazıbaşı / Torbalı / İzmir / TURKEY

Product: Air Handling Units

Model(s): KSA-1/2 (6-4), KSA-1 (6-6), KSA-2 (9-6), KSA-3 (9-9),
KSA-4 (12-9), KSA-5 (12-12), KSA-6 (15-12),
KSA-7 (18-12), KSA-8 (15-15), KSA-9 (18-15),
KSA-10 (18-18), KSA-11 (21-15), KSA-12 (24-15),
KSA-13 (21-18), KSA-14 (24-18), KSA-15 (21-21),
KSA-16 (24-21), KSA-17 (24-24), KSA-18 (27-24),
KSA-19 (27-27), KSA-20 (31-31)

Parameters: Rated Voltage : 220 - 400 VAC
Rated Frequency : 50 Hz
Rated Power : 0,25 kW – 75 kW
Air Flow Capacity : 500 m³/h-115300m³/h
Protection against Moisture : IP 55
Protection Class : I

**Product Tested
And Inspected
according to:**

98/37/AT Machinery Directive
EN 60204-1: 2006
EN ISO 12100-1: 2003
EN ISO 12100-2: 2003
EN 1050:1996

This Attestation of Conformity is issued on a voluntary basis according to Machinery Directive 98/37/AT. It conforms that the listed equipment (not Annex IV equipment) complies with the principal protection requirements of the directive. It refers only to the particular sample and its technical documentation submitted for inspection.

Test Report No.: TGK-LTMP-08-020

Date, 2008-04-18



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1

K03-E06-S01, Yayın Tarihi: 10.04.2007, Rev: 01 , Rev. Tarihi: 09.04.2007

