

Test Certificate

Abbreviated version of the survey report with order number 81 02 98 05 42

TYPE APPROVAL

**Air Handling Unit, Hygienic Version
to DIN 1946 Part 4**

Approval body TÜV NORD Systems GmbH & Co. KG
Customer KLS
Klas ISITMA SOGUTMA KLIMA SANAYI TICARET
LTD. STI
Yazibasi Beldesi Simge Cad. No. 19
Torbalı, Izmir, TURKEY
Surveyor Dipl.-Ing. Wilhelm Zickler, TÜV NORD Systems
GmbH & Co. KG, Essen

The inspections of the central air conditioning units have been performed according to DIN 1946 part 4, ("Ventilation and air conditioning, Ventilation in hospitals"). The applicable requirements of German and European standards and directives, such as DIN EN 1886, DIN EN 1751, VDI 3803 and VDI 6022 were considered.

The specimen unit inspected, from the series designated KLS-HYGIENIC, in all the unit sizes listed in the report by TÜV NORD, meets the requirements to DIN 1946 part 4 provided the requirements and notes in the operating and installation instructions are adhered to. Providing the conditions of use set forth in the contract governing the use of approval labels are observed, KLAS ISITMA SOGUTMA KLIMA SAN TIC LTD STI is granted permission to use the approval label shown here for advertising purposes.

TÜV NORD Systems GmbH & Co. KG
Central Department for
Technical Systems in Buildings

General Manager



Dr. Becker

Surveyor



Dipl.-Ing. Wilhelm Zickler

Essen, 01.03.2007

